

---

The original instrument and the following digest, which constitutes no part of the legislative instrument, were prepared by Christopher D. Adams.

---

## DIGEST

Cortez (SB 421)

Proposed law provides the office of public health of the Department of Health and Hospitals shall promulgate the appropriate rules and regulations pursuant to the Administrative Procedure Act requiring iron and manganese control for all community water systems.

Proposed law provides the maximum contaminant level in water from a community water system shall not exceed 0.3 milligrams per liter of iron and 0.05 milligrams per liter of manganese.

Effective upon signature of the governor or lapse of time for gubernatorial action.

(Adds R.S. 40:4.15)